



NOTES:

1. DOUBLE CHECK VALVE ASSEMBLY SHALL MEET REQUIREMENTS OF THE AWWA "ACCEPTED PROCEDURE AND PRACTICE IN CROSS-CONNECTION CONTROL" MANUAL.
2. DEVICES MUST BE ON STATE DEPT OF SOCIAL AND HEALTH SERVICES LIST OF "APPROVED CROSS-CONNECTION CONTROL DEVICES".
3. METER BOX SIZE SHOULD BE THE SIZE SPECIFIED FOR THE METER SIZE EQUIVALENT TO THE BACKFLOW PREVENTOR SIZE.

APPROVED: <u>SCOTT THOMASSON</u> REV. DATE: <u>JULY 28, 1999</u>			STANDARD DETAILS			
WATER/WASTEWATER DIVISION			IRRIGATION/RESIDENTIAL FIRE BACKFLOW PREVENTOR (3/4" - 2")			
			FILE	SD711.DWG	DRAWING NO.	711